TOWN OF BLOWING ROCK, NORTH CAROLINA 2014 SYSTEM PERFORMANCE ANNUAL REPORT

Collection System and Wastewater Treatment Plant

This report provides performance information on the Town of Blowing Rock sewer collection system and wastewater treatment plant in the year 2014. It is required under the provisions of the Clean Water Act of 1999, House Bill 1160 ratified on July 20, 1999.

COLLECTION SYSTEM

General Information I.

Facility Name:

Town of Blowing Rock

Responsible Entity:

Town of Blowing Rock

Person in Charge:

Marshall J. Townsend, Collection System ORC

Applicable Permits:

WQCS00142

II. **System Description**

The collection system consists of approximately 15.8 miles of gravity sewer lines and 3.4 miles of pressure sewer. There are four lift-stations; Mayview, Chetola, and Chestnut Hill, and Quail Hollow which are checked weekly.

III. Performance

There were no spills that reached surface waters associated with the collection system during the year. The Town removed several blockages during 2014, but none of which resulted in a sanitary sewer overflow. In accordance with State regulations, all spill reaching surface waters and/or are over 1,000 gallons shall be reported to the State of North Carolina, Department of Environment and Natural Resources.

BLOWING ROCK WASTEWATER TREATMENT PLANT

General Information I.

Facility Name:

Town of Blowing Rock Wastewater Treatment Plant

Responsible Entity:

Town of Blowing Rock

Person in Charge:

Mark D. Griffin, Wastewater Treatment Plant ORC

Applicable Permits:

NPDES Permit No: NC0027286

Plant Capacity:

.800 MGD

II. System Description

Wastewater is physically screened through a mechanical bar rack and then enters the equalization basin. It is then pumped by three influent pumps to four aeration basins where diffused air is added by five blowers. It then enters two clarifiers where a part of the sludge is returned to the head of the plant by two new return sludge pumps. The clear water on top of the clarifiers then enters the chlorine contact chamber where chlorine is fed to kill the bacteria. De-chlorine chemical is then added to take the chlorine out of the water before entering the river.

Solids are wasted to the new 200,000-gallon digester daily. Honeywell Septic Tank Service hauls sludge to Lenoir WWTP for disposal.

III. Performance

Average Daily Flow for 2014

| Month | Total WW Treated | Average Daily | Maximum Flow | Total Rainfall (Inches) |
|-----------|---------------------|------------------|-----------------|----------------------------|
| January | 9.991 | 0.322 | 0.471 | 12.8 |
| February | 7.058 | 0.252 | 0.359 | 3.8 |
| March | 7.418 | 0.239 | 0.302 | 2.5 |
| April | 8.478 | 0.283 | 0.348 | 5.9 |
| May | 8.387 | 0.278 | 0.533 | 4.3 |
| June | 7.928 | 0.264 | 0.346 | 4.3 |
| July | 9.774 | 0.315 | 0.401 | 3.4 |
| August | 9.44 | 0.305 | 0.430 | 4.6 |
| September | 9.175 | 0.306 | 0.559 | 9.7 |
| October | 9.975 | 0.322 | 0.631 | 8.1 |
| November | 5.915 | 0.197 | 0.334 | 5.5 |
| December | 6.46 | 0.208 | 0.313 | 5.2 |
| Total | 99.99 | 3.291 | 5.027 | 70.1 |
| Average | 8.33 | 0.274 | 0.419 | 5.81 |

2014 Results for Permit NPDES Parameters

| Parameter | Limit | Violations | Date of Violation |
|------------------------|---------------|------------|-------------------|
| PH | 6.0-9.0 Units | 0 | |
| BOD | 30/45 mg/l | 0 | |
| Total Suspended Solids | 30/45 mg/l | 0 | |
| Ammonia Nitrogen | No Limit | 0 | |
| Dissolved Oxygen | >5.0 mg/l | 0 | |
| Fecal Coliform | 200/400 mg/l | 0 | |
| Conductivity | No Limit | 0 | |
| Flow | .800 MGD | 0 | |

| Chronic Toxicity | Pass/Fail | 0 | 51 |
|------------------|-----------|---|----|
| Chlorine | 28 ug/l | 0 | |
| Total Nitrogen | NL | 0 | |
| Total Phosphorus | NL | 0 | |

IV. **Notification**

This report is available online at the website www.townofblowingrock.com for the Town of Blowing Rock. In addition copies are available for review at the Town Hall Office at 1036 Main Street, Blowing Rock, NC.

Certification V.

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.

Couch D. Spin Mark D. Griffin Water and Wastewater Treatment Plant ORC

Marshall J. Townsend Collection System ORC 1 /15 /15 Date